



খুলনা শিপইয়ার্ড লিমিটেড

বাংলাদেশ নৌ বাহিনী, খুলনা

Website: www.khulnashipyard.com, E-mail : oiocoml.ksy@gmail.com

টেন্ডার নং বাবি- ১৬/১৭৩/২৫-২৬

তারিখঃ ১২-১০-২০২৫

খোলার তারিখঃ ১৯-১০-২০২৫

বেলাঃ ১১-৩০ ঘটিকা

প্রিয় মহোদয়গণ,

নিম্নলিখিত দ্রব্যাদি খুলনা শিপইয়ার্ডে সরবরাহ করার জন্য আপনাদের কাছ থেকে সর্বনিম্ন মূল্য তালিকা আহবান করা যাচ্ছে। আপনাদের মূল্য তালিকা অবশ্যই অপর পৃষ্ঠায় বর্ণিত আমাদের শর্তাবলী অনুযায়ী হতে হবে।

আপনাদের বিশেষ

এম এম ফারুক আলম

উর্ধ্বতন বাণিজ্যিক কর্মকর্তা

পক্ষে ম্যানেজিং ডাইরেক্টর

মালামালের বিবরণ

সংযুক্ত তালিকা মোতাবেক ০২ (দুই) দফা মালামাল।

দরপত্রের সাথে চাহিদাকৃত সকল তথ্য অবশ্যই সঠিকভাবে পূরন করতে হবে এবং দরপত্র দাখিলের পূর্বে খুশিলির নমুনা সরেজমিনে পরিদর্শন করা যাবে।

দরপত্র দাখিলের দিন মালামালের নমুনা প্রদান করতে হবে, অন্যথায় দরপত্রটি বাতিল বলে গন্য হতে পারে।

বিঃ দ্রঃ ১। দরপত্রে মালামাল গুলির ব্রান্ড/ প্রস্তুতকারী দেশের নাম উল্লেখ করতে হবে। অন্যথায় দরপত্র বাতিল বলে গন্য হতে পারে।

২। টেন্ডার খোলার সময় দরদাতার কোন মতামত/ অভিযোগ থাকলে তা তাৎক্ষণিক টেন্ডার খোলার সময় টেন্ডার কমিটির নিকট উপস্থিত থেকে প্রকাশ করতে হবে। টেন্ডার খোলার পরবর্তীতে টেন্ডার সম্পর্কিত কোন অভিযোগ/ মতামত গ্রহণযোগ্য হবে না।

৩। সরবরাহের সময়সীমাঃ অনধিক ১০ দিন।

টেন্ডার কমিটির স্বাক্ষর

বাণিজ্যিক শাখা

হিসাবরক্ষণ বিভাগ

ব্যবহারকারী

আমরা অপর পৃষ্ঠায় সমস্ত শর্তাবলী মানিয়া নিলাম।

সরবরাহকারীর স্বাক্ষর

ভ্যাট নিবন্ধন নং-

এরিয়া কোড নং-

টি আই এন নং-

- ১। দরপত্র ফ্রি ডেলিভারী এন্ট্রি সাইট শর্ত ছাড়া অন্য কোন শর্তে গ্রহণযোগ্য নয়।
- ২। টেন্ডারে অংশগ্রহণকারীকে সরকারী বিধি মোতাবেক কাষ্টমস কর্তৃপক্ষের দপ্তর থেকে মূসক সেবার কোড এর ০৩৭.০০ আওতাধীন “যোগানদার” হিসাবে মূল্য সংযোজন কর/টার্নওভার ট্যাক্স নিবন্ধিত হতে হবে এবং এই টেন্ডারের সাথে মূসক/টার্নওভার ট্যাক্স নিবন্ধন পত্রের কপি সংযুক্ত করতে হবে। সরকারী বিধি মোতাবেক মূসক আদায়/রহিত করা হবে।
- ৩। সরবরাহকারীর মূল্য তালিকা (স্বহস্তে লিখিত বা ছাপানো হোক) পরিস্কারভাবে সিলমোহরকৃত খামে ম্যানেজিং ডাইরেক্টর, খুলনা শিপইয়ার্ড লিঃ বাংলাদেশ নৌ বাহিনী, খুলনা সম্বোধন পূর্বক পাঠাতে হবে। এছাড়া দরপত্র piccoml.ksy@gmail.com ই-মেইলে ঠিকানায় প্রেরণ করা যাবে (ইমেইল প্রেরণের ক্ষেত্রে) ১১.১৫ ঘণ্টিকার মধ্যে প্রেরণ করতে হবে।
- ৪। মূল্য যাচাইপত্র নং বাবি- ১৬/১৭৩/২৫-২৬ তারিখ- ১৩-১০-২০২৫ জমা নেবার শেষ তারিখ- ২০-১০-২০২৫ বেলা ১১-৩০ মিনিট পর্যন্ত।
- ৫। মূল্য তালিকা ডাকে অথবা স্বহস্তে শিপইয়ার্ড প্রধান ফটকে রক্ষিত বাক্সে জমা দিতে হবে। মূল্য তালিকা কমপক্ষে ৪০ দিন পর্যন্ত অবশ্যই বলবৎ রাখতে হবে। ক্রয়অদেশ প্রদানের তারিখ হতে ১০ দিনের মধ্যে মালামাল সরবরাহ করতে হবে।
- ৬। ক্রয়াদেশে বর্ণিত সময়সীমা উত্তীর্ণ হওয়ার পর মালামাল সরবরাহ করা হলে প্রতি সপ্তাহে অথবা অংশ বিশেষ এর জন্য ০.৫% হারে এলডি এবং সরবরাহে অধিক বিলম্বের কারনে উৎপাদন ব্যহত হলে/ কোন ক্ষতি হলে প্রতি সপ্তাহের অথবা তার অংশ বিশেষের জন্য অনাধিক ১% হারে এলডি সরবরাহকারীর নিকট হতে কর্তন করা হবে।
- ৭। সরবরাহকারী কর্তৃক সময়মত মালামাল সরবরাহে ব্যর্থ হলে অসরবরাহকৃত মালামাল অন্যত্র হতে ক্রয় করে অতিরিক্ত খরচ (যদি কিছু থাকে) সরবরাহকারীর নিকট হতে আদায় করা হবে।
- ৮। আমাদের নির্দিষ্ট মূল্য যাচাই পত্রের টেন্ডার ফরম ব্যতিরেকে অন্য যে কোন শিরোনামাংকিত পত্রের মূল্য তালিকা পাঠানো হলে উহা গ্রহণযোগ্য নাও হতে পারে। বিলম্বে প্রাপ্ত দরপত্র গ্রহণযোগ্য নয়।
- ৯। খুলনা শিপইয়ার্ড কর্তৃপক্ষের কোন কারন দর্শানো ব্যতিরেকেই যে কোন কিংবা সকল মূল্য তালিকাই গ্রহণ অথবা নাকচ করার ক্ষমতা থাকবে।
- ১০। কোন গ্রহণযোগ্য মূল্য তালিকার সরবরাহকারীকে ক্রয়াদেশ বিধি মোতাবেক দ্রব্য সরবরাহ সুনিশ্চিত করার জন্য তালিকাভুক্তি ছাড়া সরবরাহকারীর নিকট ৩% হারে জামানত আহবান করা যাবে। উক্ত জামানত এবং তালিকাভুক্ত সরবরাহকারীর স্থায়ী জামানত শিপইয়ার্ড কর্তৃপক্ষের আইনের পরিপন্থি এবং ক্রয়াদেশ বহির্ভূত যে কোন কার্যের জন্য অথ্যাৎ নির্দিষ্ট সময়ে সরবরাহে অপারগ, প্রতিজ্ঞা অথবা নমুনা কিংবা ক্রয়াদেশ মোতাবেক সরবরাহ না করার জন্য বাজেয়াপ্ত করা যাবে।
- ১১। আমাদের এই শর্তাবলী স্বীকার করে নেওয়া পর সরবরাহকারী কর্তৃক কোন প্রকার অবহেলা অথবা অন্য যে কোন নিজস্ব কারনে যদি শর্তাবলী বিঘ্নিত হয় এবং তার পরিপ্রেক্ষিতে শিপইয়ার্ডের যে কোন দ্রব্যগত বা অর্থগত ক্ষতি সরবরাহকারীর জামানত হতে পুরন করা হবে।
- ১২। সরকারী বিধি মোতাবেক ভ্যাট ও ট্যাক্স কর্তন সাপেক্ষে বিল পরিশোধ করা হবে।
- ১৩। ক্রয়াদেশভুক্ত একই দফা আংশিক সরবরাহ গ্রহণযোগ্য নহে।

সালিসীর মধ্যস্থতা

উপরোক্ত শর্তাবলীর উপর যদি কোন মত বিরোধ দেখা দেয় তবে বিষয়টি নিষ্পত্তির জন্য উভয় পক্ষের মতানুসারে একটি সালিসী পক্ষ ডাকা হবে এবং তাতে বিফল হলে বাংলাদেশ নৌ বাহিনী কর্তৃক মনোনীত সালিসী পক্ষ এবং সরবরাহকারীর মনোনীত সালিসী পক্ষের মধ্যস্থতায় নিষ্পত্তির চেষ্টা করা হবে, তাতেও বিফল হলে উভয় সালিসী পক্ষের লিখিত মনোনায়নের মাধ্যম একজন বিচারক (আম্পায়ার) নিযুক্ত করা যাবে এবং তাতেও গৃহীত সিদ্ধান্ত ব্যর্থ হলে ১৯৪০ সালের সালিসী আইন অনুযায়ী চরম সিদ্ধান্তের জন্য একটি চরম সালিসী পক্ষকে মেনে নিতে হবে এবং সেই সিদ্ধান্ত উপরে বর্ণিত শর্তাবলী আইনানুগ ভাবে সংযোজিত হবে এবং উভয়পক্ষকে মেনে নিতে হবে।

বিশেষ দৃষ্টব্য

উপরোল্লিখিত যে কোন ঘরের নির্দিষ্ট বক্তব্য হতে বিরত থাকলে সরবরাহকারীর মূল্য উদ্ধৃত বাতিল হতে পারে। মূল্য উদ্ধৃতির সকল মূল্যহার পরিস্কার ভাবে লিখতে হবে। কোনরূপ অস্পষ্টতা, অসম্পূর্ণতা অথবা পুনঃলিখনের মাধ্যমে ভুল বুঝার অবকাশ থাকলে উদ্ধৃতির উক্ত অংশটুকু বাতিল বলে গণ্য হবে।

টেন্ডার নং বাবি- ১৬/১৭৩/২৫-২৬

তারিখঃ ১৩-১০-২০২৫

খোলার তারিখঃ ২০-১০-২০২৫

ক্রঃ নং	মালামালের বিবরণ	পরিমাণ	একক দর	মোট মূল্য
১।	Motorized MCCB with all Accessories- 630A, 3P, 220V AC 1. Motorized MCCB a) Brand: Schneider Electric b) Model: NSX630N + Mic 2.3 (C63N32D630) c) Type: Motorized MCCB with Electronic Trip Unit d) Rated Current (In): 630 A e) Poles: 3P f) Breaking Capacity (Icu/Ics): 50 kA at 415V AC, 50 Hz g) Protection: Adjustable (overload & short circuit) h) Motor Mechanism: Included (for remote operation) i) Control Voltage: 220 V AC 2. Accessories for MCCB Under Voltage (UV) Coil a) Model: LV4293872 b) Function: Trips MCCB at under-voltage condition c) Manufacturer: Schneider Electric d) Country of Manufacturer: To be Mentioned 3. Auxiliary Contact / Under Voltage Auxiliary a) For remote status indication and interlocking b) Manufacturer: Schneider Electric c) Country of Manufacturer: To be Mentioned d). Quantity: 01 sets (each set includes a Motorized MCCB and its accessories). e) Documents: The supplier must submit a valid authorization certificate from Schneider Electric. f) Warranty: 01 (One) year g) Manufacturer: Schneider Electric h) Country of Origin: France i) Country of Manufacturer: To be Mentioned Specification: As per attached file Expected Delivery Time: 10 days	০২ পিস	প্রতি পিস টাঃ 1. Motorized MCCB a) Brand: b) Model: c) Type: d) Rated Current (In): e) Poles: f) Breaking Capacity (Icu/Ics): g) Protection: h) Motor Mechanism: i) Control Voltage: 2. Accessories for MCCB Under Voltage (UV) Coil a) Model: b) Function: c) Manufacturer: d) Country of Manufacturer: 3. Auxiliary Contact / Under Voltage Auxiliary a) For remote status indication and interlocking b) Manufacturer: c) Country of Manufacturer: d). Quantity: e) Documents: f) Warranty: g) Manufacturer: h) Country of Origin: i) Country of Manufacturer: Specification: Delivery Time:	টাঃ

2।	Load Break Switch (LBS) With CT & PT- 630A, 1. Load Break Switch a) Brand: To be mentioned b) Model: To be mentioned c) Rating: 630 A d) System Voltage: 11 kV e) Rated Voltage: 12 KV f) Breaking Capacity: 20 kA Minimum g) Type: Indoor type h) HT Fuse size: 40 Amp each set will be 3 pcs i) Contact material: Copper j) Operation Mechanism: Manual k) Quantity: 01 No. 2. Current Transformer (CT) a) Brand: To be mentioned b) Model: To be mentioned c) Type: Cast resin insulated, dry type d) System Voltage: 11 kV e) Ratio: 60/5 A f) Accuracy Class: To be mentioned g) Burden: Suitable for connected metering/protection devices h) Quantity: 1 Set (3 Nos.) 3. Potential Transformer (PT) a) Type: Cast resin insulated, double pole b) System Voltage: 11 kV c) Ratio: 11 kV / 110 V (as per standard practice) d) Accuracy Class: To be mentioned e) Burden: 50 VA f) Quantity: 1 Set (2 Pcs.) 4. Insulation: Khulna Shipyard Ltd. will carry out the installation of this LBS with CT & PT; however, the supplier's representative shall provide instructions and guidance if required. 5. Accessories: All necessary accessories required for smooth operation, even if not mentioned in the technical specification, will be supplied without any additional charge (if required) 6. Testing Documents: Dielectric and mechanical operation tests relevant documents should be provided with the products. G. Test-Trial: The HT LBS must undergo a test trial under actual operating conditions to verify smooth operation, insulation reliability, and load-handling capacity without malfunction. Acceptance will be granted only if all technical parameters are met, and any failure during the trial must be rectified or replaced by the supplier at cost. 7. Warranty: 01 (One) year 8. Country of Origin: To be mentioned 9. Manufacturing Country: To be mentioned	০৩ পিস	প্রতি পিস টাঃ 1. Load Break Switch a) Brand: To be mentioned b) Model: To be mentioned c) Rating: 630 A d) System Voltage: 11 kV e) Rated Voltage: 12 KV f) Breaking Capacity: 20 kA Minimum g) Type: Indoor type h) HT Fuse size: 40 Amp each set will be 3 pcs i) Contact material: Copper j) Operation Mechanism: Manual k) Quantity: 01 No. 2. Current Transformer (CT) a) Brand: To be mentioned b) Model: To be mentioned c) Type: Cast resin insulated, dry type d) System Voltage: 11 kV e) Ratio: 60/5 A f) Accuracy Class: To be mentioned g) Burden: Suitable for connected metering/protection devices h) Quantity: 1 Set (3 Nos.) 3. Potential Transformer (PT) a) Type: Cast resin insulated, double pole b) System Voltage: 11 kV c) Ratio: 11 kV / 110 V (as per standard practice) d) Accuracy Class: To be mentioned e) Burden: 50 VA f) Quantity: 1 Set (2 Pcs.) 4. Insulation: Khulna Shipyard Ltd. will carry out the installation of this LBS with CT & PT; however, the supplier's representative shall provide instructions and guidance if required. 5. Accessories: All necessary accessories required for smooth operation, even if not mentioned in the technical specification, will be supplied without any additional charge (if required) 6. Testing Documents: Dielectric and mechanical operation tests relevant documents should be provided with the products. G. Test-Trial: The HT LBS must undergo a test trial under actual operating conditions to verify smooth operation, insulation reliability, and load-handling capacity without malfunction. Acceptance will be granted only if all technical parameters are met, and any failure during the trial must be rectified or replaced by the supplier at cost. 7. Warranty: 01 (One) year 8. Country of Origin: To be mentioned 9. Manufacturing Country: To be mentioned	টাঃ
----	---	--------	---	-----

দরপত্রের সাথে অবশ্যই নমুনা দাখিল করতে হবে। অন্যথায় দরপত্র বাতিল বলে গন্য হতে পারে।